

Chloe Timm

Subject: Planning App Ref: 220877 - Unit 9, The Crumbles, Eastbourne, BN23 6JH Proposal: Demolition of existing buildings and erection of building (Class E) with Drive-Thru facility, along with landscaping, car parking and associated works

From: Alison Simmons <Alison.Simmons@lewes-eastbourne.gov.uk>

Sent: 20 December 2022 12:58

To: Chloe Timm <Chloe.Timm@lewes-eastbourne.gov.uk>

Subject: Planning App Ref: 220877 - Unit 9, The Crumbles, Eastbourne, BN23 6JH Proposal: Demolition of existing buildings and erection of building (Class E) with Drive-Thru facility, along with landscaping, car parking and associated works

Planning App Ref: 220877 - Unit 9, The Crumbles, Eastbourne, BN23 6JH Proposal: Demolition of existing buildings and erection of building (Class E) with Drive-Thru facility, along with landscaping, car parking and associated works

If the application is approved, Environmental Protection recommend that a condition is applied as follows:

“Best practicable means” shall be used to minimise noise and vibration resulting from demolition and construction operations. The developer and all contractors shall use methods of work that conform with the Code of practice for Noise and Vibration on Construction and Open Sites, BS 5228 Parts 1 and 2; 2009

Many thanks,

Alison

Alison Simmons

Specialist Advisor (Environmental Protection)
Lewes District Council and Eastbourne Borough Council
07729 115162

Town Hall, Grove Road, Eastbourne BN21 4UG 01323 410000
Southover House, Southover Road, Lewes BN7 1AB 01273 471600

Alison.Simmons@lewes-eastbourne.gov.uk
www.lewes-eastbourne.gov.uk